

## **2 INCH MONITORING STATIONS**

- Terminals on the outside of the lid provide fast, convenient test checks.
- Available with pre-wiring to outside terminals in the lid. One red and one black 15' coil of plastic coated, #12 AWG type THW, 600 volt, oil resistant solid copper wire is contained in the station.
- Wires easily uncoil to reach connection points.
- Stations with terminals but no wires is available.
- The 15" plastic box has a 2 $\frac{3}{8}$ " I.D. and is available in either straight or flanged top for installation at grade level.
- Made from SUPERIOR GRADE ABS plastic. It's long lasting and won't rust, rot or corrode.
- Adjustable to grade test stations are available upon request.
- Boxes are flared and squared to prevent pull-out, turning, or settling.
- Cast iron lids are marked "Test 1 2".
- You may order custom lids for an additional charge.
- A permanent "Real" magnet is in every box for easy location with electronic locator.
- Monitor lids available in marker posts. See marker post spec sheet to order.
- Underground installation protects the station from vandalism and is esthetically superior. However, above ground monitor stations are also available.



**HANDLEY INDUSTRIES, INC.**

## **HOW TO ORDER SUPERIOR GRADE 2" MONITORING STATIONS**

Choose from the following categories to build the monitoring station best suited to your personal needs.

ALL monitoring stations begin with **M2**.... continue to build your model number from the following categories:

# M2

**ONE = UPPER TUBE  
STYLE**

F = Plastic Flange Top  
S = Straight Top Flange

**TWO =  
WIRE**

N = Not Wired  
W = Wired

**THREE = LID  
COLOR**

(Black is Standard)  
A = Yellow

**FOUR = VENT HOLE**

L = One 3/8" Vent Hole (Mandatory for  
Group One - Code F)

**FIVE = ARCHES AND TELESCOPING BOX**

(A 15" Straight Tube, Flared at the Bottom is Standard)

Q = Telescoping Box, 18<sup>5</sup>/<sub>8</sub>" - 24", Without an Arch, Flared

R = Telescoping Box, 18<sup>5</sup>/<sub>8</sub>" - 24", With an Arch

FOR OTHER OPTIONS OR VARIATIONS, PLEASE CONSULT THE FACTORY.

